


VILLAGE OF CAHOKIA ELECTRICAL INSPECTION



INSPECTION DATE: _____

PERMIT# _____

INSPECTION TIME: _____

PHONE _____

NAME _____ ADDRESS _____

DATE PERMIT PURCHASED _____ DATE PERMIT EXPIRES _____

- UPGRADE FROM 60 AMP TO 100 AMP SERVICE.
- PER U.E. SPECIFICATIONS.
- PER I.P. SPECIFICATIONS.
- UPGRADE TO 200 AMP SERVICE.
- PER U.E. SPECIFICATIONS.
- PER I.P. SPECIFICATIONS.
- NEW PANEL MUST HAVE ROOM FOR ADDITIONAL FUTURE BRANCH CIRCUITS.
- MAIN BONDING JUMPER MAY BE WIRE, BUSS, OR SCREW.
- KITCHEN COUNTER MINIMUM 2 SEPARATE CIRCUITS FOR SMALL APPLIANCES.
(GFCI PROTECTED)
- SEPARATE CIRCUIT FOR REFRIGERATORS, MICROWAVES, DISHWASHERS, ETC....
- SEPARATE CIRCUIT FOR ELECTRIC OR GAS DRYER.
- SEPARATE CIRCUIT FOR WASHING MACHINE.
- SEPARATE CIRCUIT FOR FURNACE. MUST BE IN CONDUIT AND SWITCHED.
- SEPARATE CIRCUIT FOR CENTRAL AIR CONDITIONER OR WINDOW UNIT.
- SEPARATE CIRCUIT FOR OUTSIDE. (GFCI PROTECTED)
- SEPARATE CIRCUIT FOR ATTECHED GARAGE. (GFCI PROTECTED)
- ONE SEPARATE CIRCUIT FOR WALL RECEPTICAL-BATHROOM. (GFCI PROTECTED)
- INSTALL EXPOSED WIRING IN CONDUIT OR ABOVE CEILING.
- INSTALL SPLICED WIRING IN JUNCTION BOXES.
- INSTALL COVERS ON ALL RECEPTICLES, SWITCH BOXES AND JUNCTION BOXES.
- CHANGE OUTLETS AND SWITCHES IF PAINTED OR DAMAGED.
- NETURAL CONDUCTOR CAN NOT BE SPLIT BETWEEN 120 VOLT CIRCUITS.
- OUTLET WITH EQUIPMENT GROUND NEEDED ON MOTOR DRIVEN APPLIANCES.
- ALL CLOSET LIGHTING MUST BE FLORESENT AND HAVE PROPER COVERINGS.
- ALL CIRCUITS MUST BE IDENTIFIED AT PANEL BOX.
- OUTSIDE A/C CONDENSING UNIT MUST HAVE SERVICE DISCONNECT.
- UPGRADE SERVICE DUE TO DAMAGE OR INADEQUATE AMOUNT OF BRANCH CIRCUITS.